

Nuclear qualifications of Transduction TR-LCD5500 55" industrial 4K display monitor

1. RE102: Passed w/ low-frequency justification / level provided in Reg. Guide 1.180
2. RS103: Passed
3. CE101: Passed
4. CE102: Passed
5. CS114: Passed
6. CS101: Passed
7. Surge: Class B behavior; Passed (Image cuts out due to the presence of the Surge waveform, but comes back when the waveform is removed)
8. EFT: Class B behavior; Passed (Image cuts out due to the presence of the Surge waveform, but comes back when the waveform is removed)
9. Seismic test passed as per separate file TR-LCD5500seismicpdf.pdf
10. Electrical safety approval as per Model Code SPE 1000
11. CE tests passed with CE mark affixed for export to Europe